SIEMENS

Data sheet 3RT1955-5AS31



Changeover operating mechanism for contactors 3RT105, 3RT145 AC (50...60 Hz) / DC operation, 500 ... 550 V, Operating mechanism: Standard,economy circuit Screw terminal

General technical data	
product brand name	SIRIUS
product designation	Magnet coil
Control circuit	
type of voltage of the control supply voltage	AC/DC
control supply voltage	
● 2 at AC	
— at 50 Hz rated value	550 V
— at 60 Hz rated value	550 V
control supply voltage	
● 2 at DC rated value	550 V

Certificates/ approvals

General Product Approval	EMC	Declaration of Conformity	
CSA, UL, EAC, RCM, CE EG-Konf.			Miscellaneous

Test Certificates		Shipping Approval			other
Type Test Certificates/Test Report	Special Test Certificate	ABS	PRS	RMRS	Confirmation


other	Railway
Miscellaneous	Special Test Certificate


Further information

Information- and Downloadcenter (Catalogs, Brochures,…)


Subject to change without notice
© Copyright Siemens

https://www.siemens.com/ic10
Industry Mall (Online ordering system)
https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3RT1955-5AS31
Cax online generator
http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RT1955-5AS31
Service&Support (Manuals, Certificates, Characteristics, FAQs,...)
https://support.industry.siemens.com/cs/ww/en/ps/3RT1955-5AS31
Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)
http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3RT1955-5AS31&lang=en





© Copyright Siemens



last modified: 11/18/2020

Subject to change without notice
© Copyright Siemens